

巴厘通用能源公司 PT.GENERAL ENERGY BALI

维护部电气专业物资 技术规范书

Maintenance Department Electrical Equipment Technical Specifications

批准 (approved by) : 崔东辉

审核 (verified by) : 马金铭

编制 (Prepared by) : 高长强

采购编号 (Purchase number) : GEB-2026-P-050

第一条 总则

Article 1: General rules



1.1 本技术规范书适用于巴厘岛 3*142MW 电厂采购的物资。本技术规范书提出物资名称、规格型号、数量及验收标准等方面的技术要求。


1.1 This technical specification applies to materials procured for the 3*142MW power plant in Bali. It outlines the technical requirements for material names, specifications, quantities, and acceptance criteria.

第二条 物资名称及技术要求

Article 2: Material Name and Technical Requirements

序号 No	名称 Description	规格/型号 Specification/Model	单位 Unit	数量 Quantity	用途 Purpose	备注 Remarks
1	接近开关 proximity switch	NJ30+U1+W, 20-253V AC	个 indivua	20	卸船机 Ship unloader	
2	交直流电流继电器 AC DC current relay	JL14-11ZS 20A	个 indivua	5	除铁器控制柜 Magnetic separator control cabinet	
3	温湿度模块 Temperature and humidity module	无型号, 需根据设备型号适配 (厂家: 南京亚电) 状态显示器 型号: NYD-SSD-III(G)-2002	个 indivua	10	6kV 配电柜 6kV distribution cabinet	
4	外六角镀锌螺栓 (电缆固定卡用, 需配螺帽、垫片、弹簧垫、弹簧, 以实物图片为准) Galvanized hex bolts (for cable fixing clips; requires nuts, washers, spring washers, and springs; please refer to the actual product	M12*220mm, 强度 8.8 级	套	40	主变出线电缆用 Main transformer cable	

	image).					
5	外六角镀锌螺栓 (需配螺帽、垫片、弹簧垫) Galvanized hex bolts (require nuts, washers, and spring washers).	M12*60mm, 强度 8.8 级	套	80	励磁变 Excitation transformer	
6	外六角镀锌螺栓 (需配螺帽、垫片、弹簧垫) Galvanized hex bolts (require nuts, washers, and spring washers).	M16*60mm, 强度 8.8 级	套	80	励磁变 Excitation transformer	
7	外六角镀锌螺栓 (需配螺帽、垫片、弹簧垫) Galvanized hex bolts (require nuts, washers, and spring washers).	M12*140mm, 强度 8.8 级	套	15	励磁变 Excitation transformer	
8	电动执行器控制器 Electric actuator controller	WK-2CN0504(厂家: 扬州电力设备修造厂有限公司 Yangzhou Electric Power Equipment Manufacture Factory Co.Ltd.)	个 indiv a	2	汽机电动门 Steam Turbine Electric Door	

9	电动执行器控制板 Electric actuator control board	自仪十一 1928-01-218 (厂家: 上海自动化仪表有限公司自仪十一厂 Shanghai Automation Instrument Co., Ltd., Factory No. 11)	个 indivua	5	汽机电动门 Steam Turbine Electric Door	
10	直流电流表 DC ammeter	RQM1951-5X1(量程: ±75mV/±800A, 电压: AC/DC85-265V)	个 indivua	2	直流充电屏 DC charging screen	
11	指示灯 (绿色) Indicator light (green)	XB2-BVF3LC (电压: AC110V)	个 indivua	20	卸船机控制柜 Ship unloader control cabinet	
12	指示灯 (红色) Indicator light (red)	XB2-BVF3LC (电压: AC110V)	个 indivua	20	卸船机控制柜 Ship unloader control cabinet	
13	轴承 bearings	6202-2Z/C3	个 indivua	20	电除尘振打电机 Electrostatic precipitator rapping motor	
14	继保仪 Relay protection device	ONLY-AQ660 + 专用试验线 Dedicated test line	套 set	1	试验仪器 Test instruments	带出厂校验报告, 合格证 With factory inspection report and certificate of conformat
15	电除尘阴极振打瓷轴 Electrostatic precipitator cathode rapping ceramic shaft	总长度: 510mm 连接孔距长度: 460mm (详细规格参考附图)	个 indivua	10	电除尘 Electrostatic precipitator	
16	跳合位继电器 Trip-off relay	ARE-B332H2D (电源: DC220V, 触点容量: 250VAC 5A)	个 indivua	20	6kV 开关柜 6KV switchgear	
17	GPS 对时装置 通讯板 GPS time synchronizatio	NR1141-8-20111023 (装置型号: RCS-9785)	个 indivua	1	GPS 对时装置 GPS time synchronizatio	

	n device					
18	热继电器 thermal relay	LRE22N(Ie: 16-24A, 厂家: 施耐德)	个 indiv a	10	综合泵房控制 柜 Integrated pump room control cabinet	
19	继电器 relay	JTX-3C 250VAC 10A 线圈接点 (coil contacts): 1, 11, 厂家: 德力西	个 indiv a	20	空预器控制柜 Air preheater control cabinet	
20	冷却风机 Cooling fan	GDRM 35 133B-2 (左、右各 5 台)	台 Taiwa n	10	励磁柜 Excitation cabinet	
21	冷却风机 Cooling fan	GFD590-150 (功率: 96W, 电压: AC220V, A、B 侧各 5 台)	台 Taiwa n	10	励磁变 Excitation transformer	

第三条 质量验收标准

Article 3: Quality Inspection Standards

3.1 物资须符合国家或行业标准，确保满足甲方现场使用要求。物资到厂后，甲方有权依据本协议及相关标准对物资进行验收，如发现质量问题，乙方应无条件更换或退货。

3.1 Materials Must meet national or industry standards to ensure suitability for Party A's site use. Upon arrival at plant, Party A has the right to inspect the materials according to this agreement and relevant standards. If any quality issues are found, Party B must replace or return the goods unconditionally.

3.2 乙方须提供完整的质量检测报告、合格证及相关技术资料（到场后随带产品“三证一书”）

3.2 Party B must provide complete quality inspection reports, certificates of conformity, and relevant technical documents (Upon arrival, the product must be accompanied by the "Three Certificates and One Manual.").

第四条 责任与义务

Article 4: Responsibilities and Obligations

4.1 乙方须确保所供物资的技术参数、型号、规格与本协议一致。

4.1 Party B must ensure that the technical parameters, models, and specifications of the supplied materials comply with this agreement.

第五条 其他

Article 7: Miscellaneous

5.1 本技术规范书作为采购文件的组成部分之一，属于技术附件，与采购文件具有同等法律效力。

5.1 This technical specification is an integral part of the procurement documents and is considered a technical appendix. It has the same legal effect as the procurement documents.