

巴厘通用能源公司

PT.GENERAL ENERGY BALI

维护部汽机专业物资 技术规范书

Maintenance Department Turbine Equipment Materials Technical Specifications

批准 (approved by) : 徐东辉

审核 (verified by) : 马金铭

编制 (Prepared by) : 程嵩嵩

采购编号 (Purchase number) : GEB-2026-P-057

第一条 总则

Article 1: General rules

1.1 本技术规范书适用于巴厘岛 3*142MW 电厂采购的物资。本技术规范书提出物资名称、规格型号、数量及验收标准等方面的技术要求。

1.1 This technical specification applies to materials procured for the 3*142MW power plant in Bali. It outlines the technical requirements for material names, specifications, quantities, and acceptance criteria.

第二条 物资名称及技术要求

Article 2: Material Name and Technical Requirements

序号 No	名称 Description	规格/型号 Specification/Model	单位 Unit	数量 Quantity	用途 Purpose	备注 Remarks
1	截止阀 Stop valve	L41H-64 DN32 PN6.4	个 PCS	2	高压加热器 High-pressure heater	
2	高压蓄能器气囊 (50L) High-pressure accumulator bladder (50L)	SB330-50A1/114A	个 PCS	2	中调门 Central tone door	
3	不锈钢法兰刀闸 阀 Stainless steel flanged gate valve	PZ73F-10 DN200 316L	个 PCS	4	循环水管道 Circulating water pipeline renovation	
4	不锈钢法兰刀闸 阀 Stainless steel flanged gate valve	PZ73F-10 DN100 316L	个 PCS	4	循环水管道 Circulating water pipeline renovation	
5	不锈钢法兰盘(平 焊) Stainless steel flange (slip-on)	DN200 PN16 316L	个 PCS	10	循环水管道 Circulating water pipeline renovation	
6	无尘石棉布 Dust-free asbestos cloth	FD105 厚度 5mm	Kg	50	现场焊接防护 使用 On-site welding protection use	
7	碳氟橡胶 O 型圈 Fluorocarbon rubber O-ring	Φ170*5.5	个 PCS	10	再热热段疏水 门 Reheat the drainage valve	

8	对夹式消声止回阀 Wafer type silent check valve	DN50 PN1.6 L=72mm	个 PCS	4	消防稳压泵 Firefighting Booster Pump	
9	碳氟橡胶 O 型圈 套装 Fluorocarbon Rubber O-Ring Set	根据图片购买 Purchase based on the picture	盒 Box	5	油系统 Oil system	
10	长型球头内六方 扳手 Long ball joint internal wrench	4*144*27mm	个 PCS	10	给水泵 Safety valve for water	
11	长型球头内六方 扳手 Long ball joint internal wrench	5*144*27mm	个 PCS	10	给水泵 Safety valve for water	
12	长型球头内六方 扳手 Long ball joint internal wrench	6*144*27mm	个 PCS	10	给水泵 Safety valve for water	
13	化学气源管 Transparent plastic air supplytube	10*6.5mm 100m 一卷	卷 roll	2	化学 Chemistry	
14	定向轮 Directional wheel	8 英寸载重 5 吨 8 inches, 5-ton load	个 PCS	2	给水泵检修 Feedwater Pump Maintenance	
15	万向轮 Universal whee	8 英寸载重 5 吨 8 inches, 5-ton load	个 PCS	2	给水泵检修 Feedwater Pump Maintenance	
16	PVC 球阀 PVC ball valve	M65 与管配套 M65 compatible with the pipe	个 PCS	4	化学澄清池和 浓缩池 Chemical clarifier and thickener	
17	PVC 活套法兰片 PVC loose flange	M65 与管配套 M65compatible with the pipe	个 PCS	8	化学澄清池和 浓缩池 Chemical clarifier and thickener	
18	PVC 等径三通 PVC equal diameter tee	M65 与管配套 M65compatible with the pipe	个 PCS	3	化学澄清池和 浓缩池 Chemical clarifier and thickener	

19	PVC 直接 PVC direct	M65 与管配套 M65compatible with the pipe	个 PCS	4	化学澄清池和浓缩池 Chemical clarifier and thickener	
20	PVC 弯头 PVC elbow	M65 与管配套 M65compatible with the pipe	个 PCS	10	化学澄清池和浓缩池 Chemical clarifier and thickener	
21	PVC 直管 PVC straight pipe	Φ76*4.1	米 m	24	化学澄清池和浓缩池 Chemical clarifier and thickener	
22	轴承 bearings	RN309 轴承 (RN309M 黄铜保持架) 摆线减速机专用无外圈偏心轴承 (45*86.5*25mm)	套 set	2	化学工业废水处理间 Chemical industry wastewater treatment room	
23	耐油石棉板 Oil-resistant asbestos board	厚度=1mm	Kg	50	给水泵 Feed pump	
24	耐油石棉板 Oil-resistant asbestos board	厚度=2mm	Kg	50	给水泵 Feed pump	
25	磷酸盐加药泵检修包 Phosphate Dosing Pump Maintenance Kit	帕斯菲达计量泵 -7440-S-E 型号 PULSAFEEDER7440	套 set	2	磷酸盐加药泵 Phosphate dosing pump	
26	衬胶隔膜阀 Rubber-lined diaphragm valve	DN80 PN10 L=250mm	个 PCS	2	工业废水处理设施 Chemical industry wastewater treatment room	
27	电动抽油泵 Electric oil pump	锂电插桶泵 Lithium battery drum pump	台 pcs	2	给水泵检修 Feed pump	
28	手动抽油器 Manual oil pump		台 pcs	4	EH 油 EH oil	
29	双球可曲挠橡胶软连接 Flexible rubber connection	DN200 PN10 法兰材质 304	个 PCS	2	循环水管道 Circulating water pipeline	

	with double balls				renovation	
30	拷贝林 Copy Lin	165.1mm 8.8MPA 材质 316L(含卡箍、 胶圈、接头、螺栓)	套 set	4	海水反渗透 Seawater reverse osmosis	
31	机械密封 Mechanical seal	FEDCO MSS-24010	套 set	1	海水 RO 高压 泵检修 RO High-pressure pump	
32	轴承座	FEDCO MSS-24010	套 set	1	海水 RO 高压 泵检修 RO High-pressure pump	
33	推力盘	FEDCO MSS-24010	套 set	1	海水 RO 高压 泵检修 RO High-pressure pump	

第三条 质量验收标准

Article 3: Quality Inspection Standards

3.1 物资须符合国家或行业标准，确保满足甲方现场使用要求。物资到厂后，甲方有权依据本协议及相关标准对物资进行验收，如发现质量问题，乙方应无条件更换或退货。

3.1 Materials Must meet national or industry standards to ensure suitability for Party A's site use. Upon arrival at plant, Party A has the right to inspect the materials according to this agreement and relevant standards. If any quality issues are found, Party B must replace or return the goods unconditionally.

3.2 乙方须提供完整的质量检测报告、合格证及相关技术资料（到场后随带产品“三证一书”）

3.2 Party B must provide complete quality inspection reports, certificates of conformity, and relevant technical documents (Upon arrival, the product must be accompanied by the "Three Certificates and One Manual.").

第四条 责任与义务

Article 4: Responsibilities and Obligations

4.1 乙方须确保所供物资的技术参数、型号、规格与本协议一致。

4.1 Party B must ensure that the technical parameters, models, and specifications of the supplied materials comply with this agreement.

第五条 其他

Article 5 : Miscellaneous

5.1 本技术规范书作为采购文件的组成部分之一，属于技术附件，与采购文件具有同等法律效力。

5.1 This technical specification is an integral part of the procurement documents and is considered a technical appendix. It has the same legal effect as the procurement documents.